

GENERAL NOTES

1. GROSS AREA OF THIS DEVELOPMENT IS 76.43 ACRES.
2. TOTAL GRADED AREA IS 31.82 ± ACRES.
3. TOTAL UNDISTURBED AREA IS 44.61± ACRES.
4. TOTAL AMOUNT OF OPEN SPACE REQUIRED = 0%. TOTAL OPEN SPACE COMMON AREA = 42.68 ACRES (COMMON AREA "B").
5. COMMON AREAS / OPEN SPACE SHALL BE OWNED AND MAINTAINED BY THE H.O.A.
6. EXISTING ZONING IS R1-36.
7. SETBACKS REQUIRED/PROVIDED: FRONT=10 FEET, SIDE=5 FEET, REAR=15 FEET.
8. BUFFERYARD TYPES: BUFFERYARD 40' NATURAL . SEE TABLE ON SHEET 2.
9. ASSURANCES FOR LANDSCAPING AND RE-VEGETATION BONDS MUST BE POSTED PRIOR TO ISSUANCE OF GRADING PERMITS.
10. PROPERTY OWNER SHALL MAINTAIN SITE VISIBILITY TRIANGLE PLANTINGS TO ENSURE UNOBSTRUCTED VISIBILITY TO MOTORISTS. ALL SHRUBS, ACCENTS, AND GROUNDCOVERS SHALL NOT EXCEED THIRTY (30) INCHES IN HEIGHT WITHIN SITE VISIBILITY TRIANGLES. TREES WITHIN SITE VISIBILITY TRIANGLES WILL BE MAINTAINED TO ENSURE THAT BRANCHES / FOLIAGE ARE NOT BELOW A HEIGHT OF SIX (6') FEET.
11. LANDSCAPE MATERIALS SHALL NOT OBSTRUCT SIGHT DISTANCES OF VEHICLE TURNING MOVEMENTS.
12. IN THE EVENT OF ABANDONMENT OF THE SITE AFTER GRADING / DISTURBANCE OF NATURAL AREAS, DISTURBED AREAS SHALL BE RE-VEGETATED WITH A NON-IRRIGATED HYDRO SEED MIX FROM OVZCR ADDENDUM D: APPROVED REVEGETATION SEED MIX.
13. ALL PLANT MATERIAL SHALL MEET THE MINIMUM STANDARDS CONTAINED IN THE CURRENT EDITIONS OF THE ARIZONA NURSERY ASSOCIATION'S GROWERS COMMITTEE RECOMMENDED TREE SPECIFICATIONS AND THE AMERICAN ASSOCIATION OF NURSERYMEN AS TO SIZE, CONDITION AND APPEARANCE.
14. PROPERTY OWNER IS RESPONSIBLE FOR MAINTAINING THE TEMPORARY IRRIGATION SYSTEM AS LONG AS NECESSARY IN ORDER TO TRANSITION PLANTS OVER TO NATURAL SOURCES. ANY PLANT MATERIALS THAT DIE IN TRANSITION, FOR ANY REASONS, SHALL BE REPLACED IN ACCORDANCE WITH SECTION 27.6.E.4., MAINTENANCE.
15. LANDSCAPE SHALL CONFORM TO ORO VALLEY LANDSCAPE CODE.
16. MITIGATION OF SURVEYED PLANTS IN THE NATIVE PLANT PRESERVATION PLAN WILL BE INCORPORATED INTO THE LANDSCAPE DESIGN.
17. ALL PLANTS TO BE IRRIGATED WITH AN UNDERGROUND AUTOMATIC DRIP IRRIGATION SYSTEM.
18. HYDROSEED ALL AREAS DISTURBED BY GRADING OPERATIONS AROUND LOTS AND ALONG ROADS. DECOMPOSED GRANITE SHALL BE PLACED AT ENTRIES.
19. LANDSCAPE AREAS THAT ARE SUSCEPTIBLE TO DAMAGE BY PEDESTRIAN OR AUTO TRAFFIC SHALL BE PROTECTED BY CURBS, TREE GUARDS OR OTHER DEVICES.
20. LANDSCAPE SHALL BE DESIGNED TO MINIMIZE SEDIMENT, SAND AND GRAVEL BEING CARRIED INTO THE STREETS BY STORM WATER OR OTHER RUNOFF.
21. LANDSCAPE DESIGN ENABLES ADEQUATE PLANT SPACING TO ENSURE SURVIVABILITY AT PLANT MATURITY.
22. ALL LANDSCAPED AREAS ARE TO BE FINISHED WITH A NATURAL TOPPING OF AT LEAST TWO (2) INCHES IN DEPTH.
23. TREES AND LARGE SHRUBS SHALL BE ADEQUATELY SUPPORTED WHEN PLANTED.
24. ANY SPADED OR BOXED TREE TRANSPLANTED ON SITE THAT DIES DUE TO NEGLECT OR LACK OF MAINTENANCE SHALL BE REPLACED WITH THE SAME SIZE AND SPECIES OF THE ORIGINAL SALVAGED TREE, AS REQUIRED BY THE SALVAGE PLAN.
25. THE LIMITS OF GRADING SHALL BE STAKED IN THE FIELD, IN ACCORDANCE WITH SECTION 27.6.B.7.c.ii. DISTURBANCE OUTSIDE THE APPROVED GRADING LIMITS SHALL NOT BE PERMITTED.
26. THE DEVELOPER SHALL REPLACE REMOVED OR DAMAGED PLANT MATERIALS WITH LIKE SIZE AND SPECIES, AND SHALL MAINTAIN AND GUARANTEE THE REPLACEMENT PLANT MATERIALS FOR A PERIOD OF THREE (3) YEARS.
27. NO SALVAGE OF PLANTS REGULATED BY THE ENDANGERED SPECIES ACT AND/OR THE ARIZONA NATIVE PLANT LAW MAY OCCUR WITHOUT THE ISSUANCE OF THE APPROPRIATE PERMIT BY THE STATE DEPARTMENT OF AGRICULTURE.
28. DEEP ROOTED VEGETATION AND TREES SHALL NOT BE PLANTED CLOSER THAN 7.5 FEET FROM A PUBLIC WATER LINE. EXCEPTIONS FOR ALTERNATIVE DESIGN SOLUTIONS SUCH AS ROOT BARRIERS SHALL BE CONSIDERED ON A CASE BY CASE BASIS.
29. CURB-WAY CONSISTING OF INORGANIC GROUNDCOVER OR PLANTS NOT TO EXCEED TYPE 2 WATER USE SHALL BE PROVIDED BETWEEN THE CURB AND ALL SIDEWALKS.
30. A SEPARATE PERMIT IS REQUIRED FOR ALL LANDSCAPE AND IRRIGATION IMPROVEMENTS WITHIN PUBLIC RIGHTS OF WAY.
31. ALL DISTURBED AREAS WITHIN THE RESOURCE MANAGEMENT TIER ONE ENVELOPE SHALL BE RE-VEGETATED BACK TO NATURAL CONDITIONS USING PLANTS ON THE TOWN OF ORO VALLEY APPROVED NATIVE PLANT LIST.

SIGNIFICANT VEGETATION MITIGATION TABLE

(For all Significant Vegetation to be removed from site)

Required mitigation is per Table 27-1 and % of Significant Vegetation disturbance. 288 Significant Trees were inventoried; 72 (all non-viable) are proposed for removal. Percentage of Significant Vegetation to be removed from site (measured as the square footage of the ground cover area) is 23%. 5 Significant Saguaro (all non-viable) are proposed for removal.

Species	QTY Removed	QTY Viable	Mitigation Ratio	Replacement: Saguaro (same size or equal linear feet)	Replacement Trees (36" Box)	Replacement Trees (48" Box)	Understory Plants Required
Carnegiea gigantea (Saguaro)	5	0	N/A	0			
Olneya tesota (Ironwood)	23	0	1:1		0	0	0
Parkinsonia florida (Blue Palo Verde)	0	0			0	0	0
Parkinsonia microphylla (Foothill Palo Verde)	14	0			0	0	0
Prosopis velutina (Velvet mesquite)	35	0			0	0	0
TOTAL MITIGATION REQUIRED				0	0	0	0

Mitigation planting (if required) shall be shown on the Landscape Plan. Under-story plants shall be selected from the Supplemental Native Plant List, Addendum C, and shall either be transplanted from on-site or nursery plants.

NATIVE PLANT SUMMARY TABLE
(for all inventoried plants)

Botanical Name	Common Name	Preserve in Place (White Flagging)	Transplant (Blue Flagging)	Remove from Site (Red Flagging)	Total per Species
Carnegiea gigantea	Saguaro	163	473	20	656
Olneya tesota	Ironwood	58	187	102	347
Parkinsonia florida	Blue Palo Verde	2	1		3
Parkinsonia microphylla	Foothill Palo Verde	23	51	14	88
Prosopis velutina	Velvet Mesquite	24	25	35	84
TOTAL ALL SPECIES		270	737	171	1178


OWNER/DEVELOPER

SHANNON 80, LLC
ATTN: DAVID WILLIAMSON
3037 W. INA ROAD
TUCSON, AZ. 85741
(520) 404-7681
DAVIDW@FAIRFIELDHOMES.NET

LANDSCAPE ARCHITECT

THE WLB GROUP, INC.
4444 E. BROADWAY BLVD.
TUCSON, AZ. 85711
(520) 881-7480
ATTN: GARY GRIZZLE, PLA
GGRIZZLE@WLBGROUP.COM

FINAL LANDSCAPE PLAN
FOR
SHANNON 80 LOTS 1 THRU 80 AND COMMON AREAS
"A" (PRIVATE STREETS) &
"B" (LANDSCAPED AND NATURAL OPEN SPACE, DRAINAGE & RECREATION AREA)
1900400



PROJECT OVERVIEW

SCALE 1"= 200'


SHEET INDEX

SHEET 1	COVER SHEET
SHEET 2	OVERALL SITE PLAN
SHEET 3	PLANTING LEGEND AND WATER USE SCH.
SHEET 4 - 12	PLANTING PLAN S
SHEET 13	PLANTING DETAILS
SHEET 14	PLANTING SPECIFICATIONS
SHEET 15	IRRIGATION LEGEND AND NOTES
SHEET 16	IRRIGATION PLAN
SHEET 17	IRRIGATION DETAILS
SHEET 18	IRRIGATION DETAILS
SHEET 19	IRRIGATION SPECIFICATIONS
SHEET 20	PARK SITE PLAN
SHEET 21	RECREATIONAL AREA DETAILS
SHEET 22	RECREATIONAL AREA DETAILS

APPROVAL

ANY PLANT DEEMED SALVAGEABLE BY THE ZONING INSPECTOR SHALL BE SALVAGED. TOWN OF ORO VALLEY NATIVE PLANT SALVAGE PLAN APPROVED BY:

PLANNING & ZONING ADMINISTRATOR DATE



LOCATION MAP

A PORTION OF THE SOUTHEAST QUARTER OF SECTION 4,
T. 12 S., R. 13 E., G&SRB&M, TOWN OF ORO VALLEY,
PIMA COUNTY, ARIZONA
SCALE:3"=1 MILE

LEGEND

	EXISTING MAJOR CONTOUR
	EXISTING MINOR CONTOUR
	PROPOSED 100-YEAR FLOODPLAIN LINE
	PROPOSED EROSION HAZARD SETBACK LINE
	EXISTING 404 JD-WASH
	EXISTING RIPARIAN AREA
	SECTION LINE
	PROJECT BOUNDARY
	PROPOSED RIGHT-OF-WAY
	PROPOSED LOT LINE
	PROPOSED EASEMENT LINE AS NOTED
	EXISTING EASEMENT LINE AS NOTED
	SIGHT VISIBILITY TRIANGLE (SVT)
	EXISTING PUBLIC SEWER LINE & MANHOLE
	EXISTING PUBLIC WATERLINE & VALVE
	PROPOSED CULVERT
	EXISTING CULVERT
	EXISTING PAVEMENT
	NEW PUBLIC SEWER LINE & MANHOLE
	PROPOSED PUBLIC WATERLINE & VALVE
	PROPOSED WATER METER
	PROPOSED FIRE HYDRANT
	PROPOSED TEP EQUIPMENT
	PROPOSED STORM DRAIN W/CATCH BASIN
	PROPOSED ROCK RIPRAP
	PROPOSED ASPHALT PAVEMENT
	PROPOSED STABILIZED TREATMENT
	TOP OF SLOPE (SLOPES ≤ 3:1 UNLESS NOTED)
	BOTTOM OF SLOPE
	PROPOSED CONCRETE VERTICAL CURB
	PROPOSED CONCRETE WEDGE CURB
	PROPOSED CONCRETE SIDEWALK
	PROPOSED CURB ACCESS RAMPS
	SHEET MATCH LINE
	FLOW DIRECTION
	GRADING LIMIT
	LOT GRADING TYPE
	NEW SURVEY MONUMENT
	SECTION CORNER OR 1/4 SECTION CORNER
	BENCHMARK
	DRIVEWAY SIDE FOR SLOPED LOT/ROAD

1900400

RELATED CASE #

OV1701617
OV1701072
G-2019-042
P19W00026

SHANNON 80

LOTS 1 THROUGH 80 AND COMMON AREA "A" (PRIVATE STREETS) & "B" (LANDSCAPED & NATURAL OPEN SPACE, DRAINAGE & RECREATION AREA)

Project

FINAL LANDSCAPE PLAN
COVER SHEET

Sheet Title: File:Q:\116028 Shannon 80\A-002 - Platting\02 Landscape\08 FLP\Plans\Shannon 80 FLP 01 cover.dwg

No.	Date	Item

Scale	AS NOTED	Sheet	1
Job No.	116028-A002	of	22
Date	JULY 2020		
Designed By	PNR		
Checked By	GLG		



224-22-0210
ROBERT & BEVERLY
BUSSE JT/RS

224--22-0240
HEATHER FREGIN & JACK REDHAIR

224-22-0259
NELSON MICHEAL &
SHARON LIVING TR

224-22-0260
EISCHEID DAVID & NANCY KARIK
REVOC. LIVING TR.


224-22-0270
METELOVSKI
BORIS & CAROL
CP/RS

224-22
DINNING J PATRI
CP/H

224-22-0290
G J PATRICK & MARLIS G
CP/BS



1 **TYPICAL**
SCALE: NTS



NOTE: DETAIL SHOWN FOR GRAPHIC PURPOSES ONLY. HOUSE AND LOT SHOWN FOR CONTEXT AND DOES NOT DEPICT TRUE FIELD CONDITIONS.

A diagram showing a cross-section of a road. On the left is a sidewalk labeled "SIDEWALK". To its right is a road labeled "ROAD". To the right of the road is a road shoulder.

2 **TYPICAL**
SCALE: NTS

LOTS 1 THROUGH 80 AND COMMON AREA "A" (PRIVATE STREETS) & "B" (LANDSCAPED & NATURAL OPEN SPACE DRAINAGE & RECREATION AREA)

Project

Sheet Title File:Q:\116028 Shannon 80\A-002 - Platting\02 Landscape\08 FLP\Plans\Shannon 80 FLP 02 overview.dwg

[illegible]



Call at least two full working days
before you begin excavation.

ARIZONA 811
Arizona Blue Stake, Inc.

Dial 8-1-1 or 1-800-STAKE-IT (782-5348)
In Maricopa County: (602) 263-1100

OV1701617
OV1701072
G-2019-042
19WI00026

Engineering Planning Surveying
Landscape Architecture Urban Design
Offices located in Tucson, Phoenix and
Flagstaff, Arizona, and Las Vegas, Nevada.
4444 East Broadway
Tucson, Arizona (520) 881-7480



FOR PLANTING LEGEND SEE
SHEET 3

FRONT YARD TREES ARE
INDICATED ON SHEET 2



RELATED CASE #
OV1701617
OV1701072
G-2019-042
P19WI00026



Engineering Planning Surveying
Landscape Architecture Urban Design
Offices located in Tucson, Phoenix and
Flagstaff, Arizona, and Las Vegas, Nevada.
4444 East Broadway
Tucson, Arizona (520) 881-7480

SHANNON 80
LOTS 1 THROUGH 80 AND COMMON AREA "A" (PRIVATE STREETS) & "B" (LANDSCAPED & NATURAL OPEN SPACE,
DRAINAGE & RECREATION AREA)
Project

**FINAL LANDSCAPE PLAN
PLANTING PLAN**



Sheet Title File:Q:\116028 Shannon 80\A-002 - Platting\02 Landscape\08 FLP\Plans\Shannon 80 FLP 04 plants.dwg

No.	Date	Item

Scale	AS NOTED
Job No.	116028-A002
Date	JULY 2020
Designed By	PNR
Checked By	GLG



Sheet	4
of	22



FOR PLANTING LEGEND SEE SHEET 3

FRONT YARD TREES ARE INDICATED ON SHEET 2



RELATED CASE #
OV1701617
OV1701072
G-2019-042
P19W100026

The WLB Group Inc. **WLB**

Engineering Planning Surveying
Landscape Architecture Urban Design
Offices located in Tucson, Phoenix and
Flagstaff, Arizona, and Las Vegas, Nevada.
4444 East Broadway
Tucson, Arizona (520) 881-7480

SHANNON 80
LOTS 1 THROUGH 80 AND COMMON AREA "A" (PRIVATE STREETS) & "B" (LANDSCAPED & NATURAL OPEN SPACE, DRAINAGE & RECREATION AREA)
Project

**FINAL LANDSCAPE PLAN
PLANTING PLAN**



Sheet Title File:Q:\116028 Shannon 80A-002 - Planting\02 Landscape\08 FLP\Plans\Shannon 80 FLP 05 plants.dwg

No.	Date	Item

Scale	AS NOTED
Job No.	116028-A002
Date	JULY 2020
Designed By	PNR
Checked By	GLG



Sheet **5**
of **22**



FOR PLANTING LEGEND SEE SHEET 3

FRONT YARD TREES ARE INDICATED ON SHEET 2





RELATED CASE #
OV1701617
OV1701072
G-2019-042
P19W100026

No.	Date	Item

Scale	AS NOTED
Job No.	116028-A002
Date	JULY 2020
Designed By	PNR
Checked By	GLG





**FOR PLANTING LEGEND SEE
SHEET 3**

**FRONT YARD TREES ARE
INDICATED ON SHEET 2**



RELATED CASE #

OV1701617
OV1701072
G-2019-042
P19WI00026

The WLB Group **WLB**

Engineering Planning Surveying
Landscape Architecture Urban Design
Offices located in Tucson, Phoenix and
Flagstaff, Arizona, and Las Vegas, Nevada.
4444 East Broadway
Tucson, Arizona (520) 881-7480

SHANNON 80

LOTS 1 THROUGH 80 AND COMMON AREA "A" (PRIVATE STREETS) & "B" (LANDSCAPED & NATURAL OPEN SPACE DRAINAGE & RECREATION AREA)

Project



FINAL LANDSCAPE PLAN PLANTING PLAN

Sheet Title File:Q:\116028 Shannon 80\A-002 - Platting\02 Landscape\08 FLP\Plans\Shannon 80 FLP 07 plants.dwg

No.	Date	Item	Scale	AS NOTED
			Job No.	116028-A002
			Date	JULY 2020
			Designed By	PNP
Revisions			Checked By	GLC



Sheet 7
of 22



FOR PLANTING LEGEND SEE SHEET 3

FRONT YARD TREES ARE INDICATED ON SHEET 2



RELATED CASE #

OV1701617
OV1701072
G-2019-042
P19W100026



Engineering Planning Surveying
Landscape Architecture Urban Design
Offices located in Tucson, Phoenix and
Flagstaff, Arizona, and Las Vegas, Nevada.
4444 East Broadway
Tucson, Arizona (520) 881-7480

SHANNON 80
LOTS 1 THROUGH 80 AND COMMON AREA "A" (PRIVATE STREETS) & "B" (LANDSCAPED & NATURAL OPEN SPACE,
DRAINAGE & RECREATION AREA)
Project


**FINAL LANDSCAPE PLAN
PLANTING PLAN**

Sheet Title File:Q:\116028 Shannon 80A-002 - Planting\02 Landscape\08 FLP\Plans\Shannon 80 FLP 08 plants.dwg

No.	Date	Item



Scale	AS NOTED
Job No.	116028-A002
Date	JULY 2020
Designed By	PNR
Checked By	GLG





Sheet **9**

of **22**



FOR PLANTING LEGEND SEE SHEET 3

FRONT YARD TREES ARE INDICATED ON SHEET 2



RELATED CASE #
OV1701617
OV1701072
G-2019-042
P19W100026



Engineering Planning Surveying
Landscape Architecture Urban Design
Offices located in Tucson, Phoenix and
Flagstaff, Arizona, and Las Vegas, Nevada.
444 East Broadway
Tucson, Arizona (520) 881-7480

SHANNON 80
LOTS 1 THROUGH 80 AND COMMON AREA "A" (PRIVATE STREETS) & "B" (LANDSCAPED & NATURAL OPEN SPACE,
DRAINAGE & RECREATION AREA)
Project




**FINAL LANDSCAPE PLAN
PLANTING PLAN**

Sheet Title: File: Q:\116028 Shannon 80A-002 - Planting\02 Landscape\08 FLP\Plans\Shannon 80 FLP 10 plants.dwg

No.	Date	Item

Scale: **AS NOTED**
Job No.: **116028-A002**
Date: **JULY 2020**
Designed By: **PNR**
Checked By: **GLG**

Sheet **10**
of **22**



FOR PLANTING LEGEND SEE SHEET 3

FRONT YARD TREES ARE INDICATED ON SHEET 2



Engineering Planning Surveying
Landscape Architecture Urban Design
Offices located in Tucson, Phoenix and
Flagstaff, Arizona, and Las Vegas, Nevada.
4444 East Broadway
Tucson, Arizona (520) 881-7480

SHANNON 80

LOTS 1 THROUGH 80 AND COMMON AREA "A" (PRIVATE STREETS) & "B" (LANDSCAPED & NATURAL OPEN SPACE,
DRAINAGE & RECREATION AREA)

Project

**FINAL LANDSCAPE PLAN
PLANTING PLAN**

Sheet Title File: Q:\116028 Shannon 80\A-002 - Platting\02 Landscape\08 FLP\Plans\Shannon 80 FLP 11 plants.dwg

No.	Date	Item


Scale	AS NOTED
Job No.	116028-A002
Date	JULY 2020
Designed By	PNR
Checked By	GLG





RELATED CASE #


OV1701617
OV1701072
G-2019-042
P19WI00026

Sheet **11**
of **22**




**FRONT YARD TREES ARE
INDICATED ON SHEET 2**






CARNEGIEA GIGANTEA (CG1, CG6, G33, CG132, CG718, CG1176, CG 965, CG1178)
10 PROTECTIVE FENCING FOR SIGNIFICANT SAGUAROS PRESERVED IN PLACE
SCALE: NTS



11 BOULDER PLACEMENT
SCALE: NTS




NOTES:


1. CLEAN SAND, NO STONES, MORTAR SAND IS RECOMMENDED
2. ROOT PRUNE ALL SHRDDDED OR DAMAGED ROOTS. ENSURE ALL WOUNDS TO THE ROOT SYSTEM ARE CLEAN CUT PRIOR TO PLANTING. DUST ALL ROOTS WITH SULFUR.
3. PLANTING WELL SHALL BE 6" MIN. WIDER THAN THE EXTENT OF THE SEVERED LATERAL ROOTS.
4. PLANTING DEPTH SHALL BE THE SAME DEPTH AT WHICH THE PLANT WAS GROWN. (NO MORE THAN 3" DEEPER THAN PREVIOUSLY GROWN) THE TAPERING OF ROOT COLLAR MUST BE VISIBLE ABOVE THE FINISHED GRADE.
5. BACKFILL PLANTING WELL WITH DRY NATIVE SOIL TREATED WITH SOIL SULFUR. COMPACT SOIL IN 6" LIFTS TO ENSURE THE STABILITY OF THE BARREL CACTUS.
6. ALL BARREL CACTUS PLACEMENTS SHALL MATCH ORIGINAL NORTH SIDE FACING NORTH. ANY SUNBURNED BARREL CACTUS SHALL BE REPLACED BY THE LANDSCAPE CONTRACTOR.
7. MIST WITH WATER FROM TOP DOWN ONCE A MONTH IF PLANTED DURING HOT SEASON
8. AFTER TRANSPLANTING, ALLOW 2-3 WEEKS BEFORE FIRST WATERING.

7 BARREL CACTUS PLANTING DETAIL
SCALE: NTS


- NOTES:
1. FINISHED DEPTH: 2" MIN.
 2. BEFORE SPREADING ROCK, REMOVE ROCK & DEBRIS.
 3. DURING INSTALLATION RAKE D.G. TO SETTLE FINES.
 4. LIGHTLY BROOM SURFACE OF D.G. AFTER INSTALLATION.
 5. APPLY PRE-EMERGENT TO ALL D.G. AREAS.
 6. APPLY A LIGHT MIST OF WATER OVER THE ENTIRE D.G. SURFACE.



8 INERT GROUNDCOVER
SCALE: NTS




9 DECOMPOSED GRANITE AT CONCRETE
SCALE: NTS



NOTES:

1. CLEAN SAND, NO STONES. MORTAR SAND IS RECOMMENDED
2. ROOT PRUNE ALL SHRDDDED OR DAMAGED ROOTS. ENSURE ALL WOUNDS TO THE ROOT SYSTEM ARE CLEAN CUT PRIOR TO PLANTING. DUST ALL ROOTS WITH SULFUR.
3. PLANT SAGUARO AT LEAST 4' FROM SHRUBS OR TREES.
4. PLANTING WELL SHALL BE 6" MIN. WIDER THAN THE EXTENT OF THE SEVERED LATERAL ROOTS. CUT THROUGH TAPROOT TO PROVIDE A FLAT BASE WITH A DIAMETER SUFFICIENT TO SUPPORT THE WEIGHT OF THE UNSUPPORTED SAGUARO.
5. PLANTING DEPTH SHALL BE MAXIMUM OF 3" DEEPER THAN THE DEPTH AT WHICH THE PLANT WAS GROWN. THE TAPERING OF ROOT COLLAR MUST BE VISIBLE ABOVE THE FINISHED GRADE.
6. BACKFILL PLANTING WELL WITH DRY NATIVE SOIL TREATED WITH SOIL SULFUR. COMPACT SOIL IN 6" LIFTS TO ENSURE THE STABILITY OF THE SAGUARO.
7. ALL SAGUARO PLACEMENTS SHALL MATCH ORIGINAL NORTH SIDE FACING NORTH. ANY SUNBURNED SAGUAROS SHALL BE REPLACED BY THE LANDSCAPE CONTRACTOR.
8. SAGUAROS ARE SPECIFIED BY HEIGHT. A VARIETY OF HEIGHTS MAY BE ACCEPTABLE PROVIDED THE AVERAGE IS NOT LESS THAN SPECIFIED. OWNER MUST APPROVE SAGUAROS PRIOR TO PLANTING.
9. MIST WITH WATER FROM TOP DOWN ONCE A MONTH IF PLANTED DURING HOT SEASON
10. AFTER TRANSPLANTING, ALLOW 2-3 WEEKS BEFORE FIRST WATERING.


5 COLUMNAR CACTUS PLANTING
SCALE: NTS



NOTES:


1. ROOT PRUNE ALL SHREDDDED OR DAMAGED ROOTS.
2. ENSURE ALL WOUNDS TO THE ROOT SYSTEM ARE CLEAN CUT BEFORE PLANTING.
3. APPLY DUSTING SULFUR TO ALL AREAS BELOW GRADE.
4. BARE ROOTS SHALL NOT BE OUT OF THE GROUND FOR MORE THAN FIVE DAYS.
5. MIST WITH WATER FROM TOP DOWN EVERY OTHER WEEK IF PLANTED DURING HOT SEASON.

6 OCOTILLO PLANTING
SCALE: NTS




NOTE: 1. WATER SETTLE BACKFILL 6" LIFTS

1 SHRUB PLANTING
SCALE: NTS




NOTE: 1. WATER SETTLE BACKFILL IN 6" LIFTS

2 SHRUB PLANTING ON SLOPE
SCALE: NTS



NOTE: 1. REMOVE ALL NURSERY STAKES AND CONTAINERS
2. WATER SETTLE BACKFILL IN 6" LIFTS

3 TREE PLANTING
SCALE: NTS



NOTE: 1. REMOVE ALL NURSERY STAKES AND CONTAINERS
2. WATER SETTLE BACKFILL 6" LIFTS

4 TREE PLANTING ON SLOPE
SCALE: NTS

RELATED CASE #

OV1701617
OV1701072
G-2019-042
P19WI00026



The WLB Group Inc.

Engineering Planning Surveying
Landscape Architecture Urban Design
Offices located in Tucson, Phoenix and
Flagstaff, Arizona, and Las Vegas, Nevada.
4444 East Broadway
Tucson, Arizona (520) 881-7480

SHANNON 80

LOTS 1 THROUGH 80 AND COMMON AREA "A" (PRIVATE STREETS) & "B" (LANDSCAPED & NATURAL OPEN SPACE, DRAINAGE & RECREATION AREA)
Project

**FINAL LANDSCAPE PLAN
PLANTING DETAILS**

Sheet Title File:Q:\116028 Shannon 80\A-002 - Planting\02 Landscape\08 FLP\Plans\Shannon 80 FLP 13 Dets.dwg

No.	Date	Item	Scale
			Job No. 116028-A002
			Date JULY 2020
			Designed By PNR
			Checked By GLG



Sheet 13
of 22

LANDSCAPE WORK

PART 1 - GENERAL

1.1 SUMMARY

- A. This Section includes the following:
1. Seeding.
 2. Sodding.
 3. Trees, Shrub and Cacti.
 4. Inert Ground Cover.

1.2 SUBMITTAL REQUIREMENTS

- A. General: The Contractor shall make the submittals identified below. Submittals shall be approved prior delivery or placement of materials.
- B. Certificates of Compliance: Submit 3 copies of the following certificates of compliance to the Owner's Representative for review and approval:
1. Fertilizer, Soil Sulfur, Gypsum, Manganese Sulfate: Manufacturer's certified statement of analysis for each.
 2. Organic Soil Conditioner: A certificate, signed by the supplier, stating that the product complies with the project specifications
 3. Soil Stabilizer: Manufacturer's certified statement of analysis.
- C. Materials Test Reports: for existing surface soil and imported soil.
- D. Certification of Grass Seed: From seed vendor for each grass-seed monostand or mixture stating the botanical and common name and percentage by weight of each species and variety, and percentage of purity, germination, and weed seed. Include the year of production and date of packaging.
1. Certification of each seed mixture for turfgrass sod, identifying source, including name and telephone number of supplier.

- E. Samples for Verification: For each of the following provide the following samples:
1. 5 lb of decomposed granite mulch for the color and gradation of decomposed granite proposed for use on the project, in labeled plastic bag.

1.3 COMPLIANCE WITH APPLICABLE REGULATIONS

- A. The Contractor shall comply with all local, state, and federal regulations regarding materials, methods of work, and disposal of excess and waste materials. The Contractor shall provide notices required by all governmental authorities, request required inspections, obtain required permits, and pay for all associated fees.

1.4 QUALITY ASSURANCE

- A. Installer Qualifications: All work shall be performed by a Contractor licensed by the State of Arizona Register of Contractors. The commercial license held by the Contractor shall be appropriate for the work being performed.
1. The Contractor shall maintain an experienced full-time supervisor on Project site during the construction period.
- B. Observation: Owner's Representative may observe plants either at place of growth or at site before planting for compliance with requirements for genus, species, variety, size, and quality. Owner's Representative retains right to observe plants further for size and condition of balls and root systems, insects, injuries, and latent defects and to reject unsatisfactory or defective material at any time during progress of work. Remove rejected plants immediately from Project site. Owner's Representative may observe any and all plant pits prior to backfilling or planting.

1.5 DELIVERY, STORAGE, AND HANDLING

- A. Do not prune trees, shrubs and cacti before delivery, except as approved by Owner's Representative. Protect bark, branches, and root systems from sun scald, drying, sweating, whipping, and other handling and tying damage. Do not bend or bind-tie trees, shrubs or cacti in such a manner as to destroy their natural shape. Provide protective covering of plants during delivery. Do not drop plants during delivery.
- B. Deliver plants after preparations for planting have been completed and install immediately. If planting is delayed more than six hours after delivery, protect from weather and mechanical damage, and keep roots moist. Do not remove container-grown stock from containers before time of planting.
- C. Inorganic Soil Amendments: Deliver in original sealed, labeled, and undamaged containers.
- D. Fertilizer: Deliver in original sealed, labeled, and undamaged containers.
- E. Sod: Harvest, deliver, store, and handle sod according to requirements in TPI's "Specifications for Turfgrass Sod Materials" and "Specifications for Turfgrass Sod Transplanting and Installation" in its "Guideline Specifications to Turfgrass Sodding."
1. Sod shall be harvested, delivered to site, and installed, within a 24-hour period.
 2. Sod shall be kept moist, protected from wind and sun from the time of cutting to the time of installation.

1.6 COORDINATION

- A. Weather Limitations: Proceed with planting only when existing and forecasted weather conditions permit.
- B. Work that is completed or in-progress shall be protected during installation of landscape work. The Contractor shall coordinate all landscape related work with the Owner's Representative.

1.7 GUARANTEE

- A. The Contractor shall guarantee all Contractor provided plants for the period indicated, commencing on the date of Final Acceptance, against all defects including death and unsatisfactory growth, except for defects resulting from lack of adequate maintenance, neglect, or abuse by Owner, causes deliberate, or incidents that are beyond Contractor's control.
1. Guarantee Period for Trees, Shrubs and Cacti: One year from date of Substantial Completion.
 2. Guarantee Period for Turf: ninety days from date of Substantial Completion. Remove dead plants immediately. Replace immediately unless directed otherwise by Owner's Representative.
 3. Replace plants that are diseased, or that exhibit more than 25 percent die-back, at end of guarantee period.
 4. A limit of one replacement of each plant will be required, except for losses or replacements due to failure to comply with requirements.
 5. Include the following remedial actions for turf as a minimum:
 - a. Immediately remove dead turf and replace.
 - b. Repair failed areas due to erosion, replace erosion control materials in failed areas.
 - c. Sod bare seeded areas or other by methods acceptable to Owner's Representative.

1.8 MAINTENANCE DURING CONSTRUCTION

- A. The Contractor shall maintain throughout the construction period all trees, shrubs, cacti, decomposed granite, and other landscape improvements. Maintenance during construction shall continue until the issue of a Certificate of Substantial Completion. All maintenance and plant replacements throughout the construction period shall be at no additional cost to the Owner.
1. Trees, Shrubs and Cacti: During the construction, maintain by pruning, cultivating, watering, weeding, fertilizing, restoring planting saucers, tightening and repairing stakes and guy supports, clean-up and resetting to proper grades or vertical position, as required to establish healthy, viable plantings. Spray as required to keep trees, shrubs, and cacti free of insects.
 2. Turf: Begin maintenance immediately after each area is planted and continue until acceptable lawn is established, but for not less than the following periods:
 3. Maintain and establish lawn by watering, fertilizing, weeding, mowing, trimming, replanting and other operations. Roll, regrade, and replant bare or eroded areas and re-mulch to produce a uniformly smooth lawn.
 4. Turf Watering: Schedule watering to prevent wilting, puddling, erosion, and displacement of seed or mulch. Lay out temporary watering system to avoid walking over muddy or newly planted areas.
 5. Mowing: Mow lawn as soon as top growth is tall enough to cut. Repeat mowing to maintain specified height without cutting more than 40 percent of grass height. Remove no more than 40 percent of grass-leaf growth in initial or subsequent mowings. Do not delay mowing until grass blades bend over and become matted. Do not mow when grass is wet. Schedule initial and subsequent mowings to maintain supplier's recommended growing height:
 6. Lawn Postfertilization: Apply fertilizer after initial mowing and when grass is dry.
 7. Use fertilizer that will provide actual nitrogen of at least 1 lb/1000 sq. ft. to lawn area.
 8. Decomposed Granite (including stabilized and field mixes): During the construction, maintain by raking, weeding, recompacting, reapplying, regrading, and repairing eroded areas. Protect field areas from traffic.
- B. Inspection of Completed Landscape Work: Upon completion of the landscape work, the Contractor shall notify the Owner's Representative who will schedule an inspection of the landscape improvements. During the inspection, items which are incomplete or which must be repaired or replaced will be identified. Completion or correction of items noted will be required prior to the issuance of a Certificate of Substantial Completion.

1.9 MAINTENANCE AFTER SUBSTANTIAL COMPLETION

- A. Maintenance Period: Six months from date of Substantial Completion for trees, shrubs, cactus and other landscape improvements. All work shall be performed in a professional manner within the standards of the industry, using quality equipment methods and materials.
- B. Initial Turf Maintenance Service: Provide full maintenance by skilled employees of landscape installer. Maintain as required in Part 3. Begin maintenance immediately after each area is planted and continue until acceptable turf is established but for not less than the following periods:
- a. Maintain until 60 days after Substantial Completion of turf.
- C. Stand of Sodded Turf: A stand of turf from the sodding operation is defined as a healthy, well-rooted, even-colored, viable turf area, free of weeds, open joints, bare areas, and surface irregularities.
- D. Re-establish turf that does not comply with requirements and continue maintenance until turf meet the above standards.
- E. At the end of the turf maintenance period (after substantial completion), a final inspection will be made. Final acceptance of the turf will be based upon a satisfactory stand of turf as defined above. Rejected areas shall be replanted or repaired as directed by the Owner.
- F. Work Schedule: Contractor will supply the Owner's Representative with a proposed schedule of the expected day and time tasks listed below will be performed. This schedule shall be approved prior to project maintenance commencement.
- | Item No. | Task | Work Item Description | Task | Work Item Description | Time Frame |
|----------|------------------------------------|-----------------------|-----------|-----------------------|------------|
| 1 | Prune Plants | Once | 4th Month | | |
| 2 | Mow and Edge Turf | Weekly | | | |
| 3 | Fertilize Plants | Once | 4th Month | | |
| 4 | Fertilize Turf | 6 Weeks | | | |
| 5 | Irrigate Plants | Adjust per Season | | | |
| 6 | Irrigate Turf | Adjust per Season | | | |
| 7 | Weed All Areas | 2x Month | | | |
| 8 | Apply Pre-Emergent Herbicide | Once | 4th Month | | |
| 9 | Ensure Soil Conditions | Once | 2nd Month | | |
| 10 | Re-Sod Bare Areas | As Needed | | | |
| 11 | Insect, Rodent and Disease Control | Monthly | | | |
| 12 | Granite Areas | Monthly | | | |
| 13 | Police Site | Weekly | | | |
- The frequencies of the tasks stated above are suggested minimums only. During extremely wet or dry periods, the Contractor must adjust schedules to ensure correct and proper conditions are maintained.

- G. After satisfactory completion of the maintenance period, the Owner will assume responsibility for landscape maintenance

1.10 SUSPENSION OF MAINTENANCE PERIOD FOR NON-COMPLIANCE

- A. Failure to comply with the specified maintenance requirements, as determined by the Owner's representative, may result in the suspension of the maintenance period until such time as the required remedial actions have been completed by the Contractor. A number of days equal to the number of days of the suspension will be added to the maintenance period.

PART 2 - PRODUCTS

2.1 TREE, SHRUB, AND CACTI MATERIAL

- A. General: All Contractor-provided plants used on the project shall be subject to the Owner's review and approval.
- B. Plant Form and Quality: All plants shall comply with the project specifications, be normally developed individuals of their species. Provide well-shaped, fully branched, healthy, vigorous stock free of disease, insects, eggs, larvae, and defects such as knots, sun scald, injuries, abrasions, and disfigurement.
- C. Grade: Provide quality, size, genus, species, and variety of plants indicated, complying with applicable requirements in ANSI Z60.1, "American Standard for Nursery Stock" or Arizona Nurseryman's Association Recommended Average Tree Specifications", whichever is the more stringent. Trees, shrubs, and cacti of a larger size may be used if acceptable to Owner's Representative and at no additional cost to Owner.
- D. Plant Root Systems: All plants shall have healthy root systems. Container-grown plants shall have been in containers for a sufficient time for the root system to hold the soil when the plant is removed from the container, but not long enough for the plant to become root-bound or to cause a hardening of the root system.
- E. Label at least one tree, shrub, and cacti of each variety and caliper with a securely attached, waterproof tag bearing legible designation of botanical and common name.

2.2 TURFGRASS SOD

- A. Turfgrass Sod: Variety shall be as specified on the landscape plans. Turf shall be certified, complying with "Specifications for Turfgrass Sod Materials" in TPI's "Guideline Specifications to Turfgrass Sodding."
1. Furnish viable sod of uniform density, color, and texture, strongly rooted, and capable of vigorous growth and development when planted. Sod shall be certified and provided in rolls (large in open/flat areas).
- B. Overseeding: As determined by Owner's Representative, sod sod installed during the dormant season of the specified warm-season grass shall be over-seeded with perennial Rye grass to standards normal for the turfgrass industry.

2.3 PREPARED PLANTING SOIL MIX FOR TREES, SHRUBS, AND CACTI

- A. Planting Soil Mix: Planting soil shall be native topsoil mixed to a uniform volume and loose measure, with the following soil amendments and fertilizers in the following quantities per cubic yard:
1. Trees and Shrubs: 20 cubic feet of (native) topsoil, 7 cubic feet of organic soil conditioner, 2 lbs soil sulfur, 1 lb of fertilizer (16-20-0). The prepared planting soil shall be thoroughly blended prior to placement in plant pits.
 2. Cacti: Planting soil shall be native topsoil with 0.25 lbs of soil sulfur incorporated into the soil backfill at each cactus.
 3. Turf: Verify suitability of proposed soil to produce viable planting soil by taking samples and providing soil sample analysis. Remove stones, roots, plants, sod, clods, clay lumps, pockets of coarse sand, concrete slurry, concrete layers or chunks, cement, plaster, building debris, and other extraneous materials harmful to plant growth. Mix surface soil with the required soil amendments and fertilizers to produce a high quality planting soil for sod and seed areas at a depth of 4 inches.

2.4 FERTILIZER

- A. General Requirements: All fertilizers used on the project shall be in pelleted form and of recent manufacture.
- B. Slow-Release Fertilizer for Tree and Shrub Planting: Ammonium Phosphate consisting of 50 percent water-insoluble nitrogen, and phosphorus in the following composition:
1. Composition: 16 percent nitrogen, 20 percent phosphoric acid by weight.

2.5 INERT GROUND COVER

- A. Decomposed Granite: Decomposed granite shall be durable granite material size as shown on the plan. Except as may be approved by the Owner's Representative, all materials used on the project shall be from the same source and shall match the approved sample. Decomposed granite shall be free of loam, sand, clay, and other foreign substances.
1. Type: As indicated on plans.

2.6 TREE STAKING

- A. Tree Stakes: Tree Stakes shall be 2-inch (minimum) diameter by 8 feet (minimum) long peeled Lodge Pole Pine stakes. Treat with an EPA approved wood preservative. If required to support properly trees used on the project, stakes longer than specified shall be used at no cost to the Owner.
- B. Tie Wire: 12 gauge, annealed, galvanized wire.
- C. Chafing Guard: Biodegradable cotton tree ties with brass eyelet, provided in lengths required to protect tree trunks from damage. Cut tree ties be free of damage.

2.7 HORTICULTURAL CHEMICALS

- A. Pre-Emergent Herbicide: "Surflan" or "Pendulum", or approved equal. Delivered in original, sealed, and fully labeled containers and mixed according to manufacturer's written instructions.
- B. Post-Emergent Herbicide: "Round-Up", or approved equal. Delivered in original, sealed, and fully labeled containers and mixed according to manufacturer's written instructions.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine areas to receive plants and decomposed granite for compliance with requirements and conditions affecting installation and performance. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 BLUE STAKING

- A. The Contractor shall have the work area Blue-Staked prior to the start of any excavation work. Blue Staking shall be kept current throughout the course of the work. All utilities damaged by the Contractor shall be repaired or replaced by the Contractor, as required by the Owner or applicable utility company, at the Contractor's expense.

3.3 SITE PREPARATION

- A. Protect structures, utilities, sidewalks, pavements and other facilities and existing plants from damage caused by landscape operations.
- B. Provide erosion-control measures to prevent erosion or displacement of soils and discharge of soil-bearing water runoff or airborne dust to adjacent properties and walkways.
- C. Lay out individual tree locations. Stake locations, adjust locations when requested, and obtain Owner's Representative's acceptance of layout before planting. Make minor adjustments as required.

3.4 TREE AND SHRUB PIT EXCAVATION

- A. Seasonal Limitations: The planting of trees and shrubs may be done at any time selected by the Contractor consistent with the overall project schedule. Planting during excessively hot, cold, or windy weather shall be at the Contractor's risk. Plants that die or are damaged as a result of weather conditions shall be replaced by the Contractor at no additional cost to the Owner.
- B. Excavation of Plant Pits: Excavate circular pits with sides sloped inward, pit size according to the drawings. Do not disturb sub-grade. Scarify sides of plant pit if smeared or smoothed during excavation.
- C. Subsoil removed from excavations may be amended as specified and used as backfill.
- D. Obstructions: Do not install any plant if a large obstruction is encountered below the rootball. Notify Owner's Representative if unexpected rock or obstructions detrimental to trees, shrubs or cactus are encountered in excavations.
- E. Tests for Drainage: Partially fill plant pits with water and allow water to percolate away. For acceptance, all pits shall drain at least 6" per hour. All pits not draining at 6" per hour shall be deepened or relocated as directed by Owner's Representative. Drainage testing for up to 25 percent of all tree pits shall be performed by the Contractor at no additional cost to the Owner.
1. Deepening Tree Pits: Drill 6-inch diameter holes into free-draining strata or to a depth of ten feet, whichever is less, and backfill with free-draining material.
 2. Deepening all tree pits shall be performed by the Contractor at no additional cost to the Owner.

3.5 TREE AND SHRUB PLANTING

- A. Set container-grown stock plumb and in center of pit or trench with top of root ball one inch above adjacent finish grades. Plants that settle shall be excavated and re-planted at correct grade.
1. Carefully remove root ball, immediately prior to planting, from container, without damaging root ball, stems or foliage. Damaged plants shall be replaced by the Contractor at no additional cost to the Owner.
 2. Backfill planting soil mix around root ball in layers, tamping to settle mix and eliminate voids and air pockets. When pit is approximately one-half backfilled, water thoroughly before placing remainder of backfill. Repeat watering until no more water is absorbed. Water again after placing and tamping final layer of planting soil mix.

3.6 TREE AND SHRUB PRUNING

- A. Prune, thin, and shape trees and shrubs according to standard horticultural practice. Unless otherwise indicated by Owner's Representative, do not cut tree leaders; remove only injured or dead branches. Prune shrubs to ANA Standards to retain natural character. Shrub sizes indicated are sizes after pruning.
1. All dead wood, suckers, broken or bruised branches shall be removed.
 2. Pruning shall be carried out with clean, sharp tools.
 3. If, in the opinion of the Owner's Representative, pruning results in a plant not natural in character, the plant shall be replaced by the Contractor at no additional cost to the Owner.

3.7 TREE STAKING

- A. Upright Staking and Tying: Stake trees as detailed on the drawings. Use a minimum of 2 stakes of length required to penetrate at least 18 inches below bottom of backfilled excavation and to extend at least 72 inches above grade. Set vertical stakes and space to avoid penetrating root balls or root masses. Support trees with two tree ties at contact points with tree trunk. Allow enough slack to avoid rigid restraint of tree. Use the number of stakes shown on the drawings.
1. Staking and tying shall be capable of supporting the plant, without repair, for two years.

3.8 PREPARATION OF TURF GRASS AREAS

- A. Subgrade Preparation: Rip or scarify subgrade to a minimum depth of 8 inches. If necessary, make a second pass at 90 degrees to the first. Remove stones larger than one inch in any dimension and sticks, roots, rubbish, and other extraneous matter and legally dispose of them off Owner's property. Rock removal shall be repeated after the irrigation system has been made operational and initial irrigation cycles have been conducted.
1. Apply post-emergent herbicide as directed by the Owner's Representative and according to manufacturer's written instructions.
 2. Mix soil amendments thoroughly into top 6 inches of soil immediately after application. Till soil to a homogeneous mixture of fine texture.
 3. In order to prevent settlement following planting of the turf, Contractor shall settle and compact tilled area to approximately 85 percent maximum density. This shall be accomplished by water settling, rolling or other methods necessary to ensure all voids are removed and soil has attained final settlement. Contractor will be responsible for repairs of any areas that settle following planting operations or during the guarantee period.
- B. Final Physical Nature: Upon completion of the tillage settlement operation and soil plating, the physical nature of the soil shall be such as to permit a water infiltration rate of not less than 0.6 inches per hour. Contractor shall verify this condition has been met. There shall be no sticks or debris, and no soil clods larger than 1 inch following the tillage operation.
1. Turf areas shall be filled as needed or have surplus soil removed to attain the proper finished grade. Drainage patterns and finish grades shall be maintained per plan. Turf areas compacted by construction operations shall be completely pulverized by tillage.
 2. Turf areas shall have debris and stones larger than 1/2 inch in any dimension removed from the surface, as well as larger stones visible from the surface.
 3. Grade planting areas to a smooth, uniform surface plane with loose, uniformly fine texture. Roll and rake, remove ridges, and fill depressions to meet finish grades. Limit fine grading to areas that can be planted in the immediate future.
 - a. Grade to within plus or minus one half of a foot of finish elevation. In field areas the surface shall not vary more than 3/4 inch from the bottom edge of a 10 foot straight-edge placed on the prepared surface.
 - b. Softball fields shall be fine graded using laser leveling devices.
 4. Irrigate prepared turf areas before planting. Water thoroughly and allow surface to dry before planting. Do not create muddy soil.
 5. Restore areas if eroded or otherwise disturbed after finish grading and before planting.

3.9 SODDING

- A. Schedule: Sod that is not overseeded shall be planted after May 25 and before July 15. Overseeded sod may be planted at any time of year that is consistent with the overall project schedule. Sodding of turf grass areas shall not commence until irrigation the turf system is operational.
- B. Lay sod within 24 hours of harvesting. Do not lay sod if dormant or if ground is frozen or muddy.
- C. Lay sod to form a solid mass with tightly fitted joints. Butt ends and sides of sod; do not stretch or overlap. Stagger sod strips or pads to offset joints in adjacent courses. Avoid damage to subgrade or sod during installation. Tamp and roll with a water-filled hand-propelled drum roller to ensure contact with subgrade, eliminate air pockets, and form a smooth surface. Open joints shall be top-dressed with clean sand; remove excess sand to avoid smothering sod and adjacent grass. Irrigate sod immediately after planting. Thereafter keep sod continuously moist until turf is established

3.8 INORGANIC SURFACING INSTALLATION

- A. Decomposed Granite Surfacing: All areas to be surfaced with decomposed granite shall be brought to the lines and grades shown on the plans, with allowance made for depth of the decomposed granite. Install decomposed granite in accordance with the project drawings.
1. A reveal shall be provided adjacent to paved surfaces as shown on the project drawings. Where not detailed, the reveal shall be 1/4 inch.

3.9 HORTICULTURAL CHEMICALS

- A. Herbicides: Herbicides shall be applied according to manufacturer's written instructions by an Applicator licensed by the state of Arizona.

3.10 CLEANUP AND PROTECTION

- A. During landscape operations, keep adjacent paving and construction clean and work area in an orderly condition.
- B. Protect all plants and decomposed granite areas from damage due to landscape operations, operations by other contractors and trades, and others. Maintain protection during installation and maintenance periods. Treat, repair, or replace damaged items.
- C. Promptly remove soil and debris created by landscape work from paved areas. Clean wheels of vehicles before leaving site to avoid tracking soil onto roads, walks, or other paved areas.
- D. Erect barricades and warning signs as required, to protect newly landscaped areas from traffic.

3.11 DISPOSAL

- A. Disposal: Remove surplus soil and waste material, including excess subsoil, unsuitable soil, trash, and debris and trimmings, and dispose of them legally off Owner's property.

1. IRRIGATION AND/OR WATERING PLANS SHALL MEET THE MINIMUM STANDARDS OF THE AMERICAN SOCIETY OF IRRIGATION CONSULTANTS.
2. IF DESERT LANDSCAPING IS USED WHICH WILL ULTIMATELY RELY ON NATURAL WATER SOURCES, A TEMPORARY DRIP IRRIGATION SYSTEM SHALL BE EMPLOYED UNTIL SUCH TIME AS THE PLANT MATERIALS ARE SUSTAINED BY NATURAL WATER SOURCES.
3. THE PROPERTY OWNER IS RESPONSIBLE FOR MAINTAINING THE TEMPORARY SYSTEM AS LONG AS NECESSARY IN ORDER TO TRANSITION PLANTS OVER TO NATURAL SOURCES. ANY PLANT MATERIALS THAT DIE IN TRANSITION, FOR ANY REASON, SHALL BE REPLACED (SECTION 27.6.E.4).
4. IRRIGATION SYSTEMS CONNECTED TO POTABLE WATER MAINS (PUBLIC OR PRIVATE) SHALL BE EQUIPPED WITH BACKFLOW PREVENTERS.
5. THE ANNUAL WATER USE FOR A PROJECT SHALL NOT EXCEED THE ANNUAL LANDSCAPE WATER PLAN
6. IRRIGATION METER READINGS SHALL BE USED TO DETERMINE COMPLIANCE WITH THE LANDSCAPE WATER PLAN. NON-COMPLIANCE IS SUBJECT TO PENALTIES UNDER THE ZONING CODE
7. METER READINGS SHALL BE TAKEN, AT A MINIMUM, ON AN ANNUAL BASIS. MONTHLY READINGS MAY BE REQUIRED, AT THE DISCRETION OF THE PLANNING AND ZONING ADMINISTRATOR, IN ORDER TO ADDRESS NON-COMPLIANCE WITH THE WATER PLAN.
8. AN INITIAL METER READING SHALL BE TAKEN PRIOR TO THE ISSUANCE OF THE CERTIFICATE OF OCCUPANCY AND RECORDED FOR REFERENCE AS PART OF THE WATER PLAN.
9. IRRIGATION WATER SHALL NOT LEAVE THE LANDSCAPED AREAS AND FLOW ONTO ROADS, PARKING AREAS OR SIDEWALKS.
10. ALL VEGETATION LOCATED IN BUFFER YARDS SHALL NOT RECEIVE IRRIGATION WATER AFTER FIVE (5) YEARS FROM THE CERTIFICATE OF OCCUPANCY DATE.

1. ALL WATER USE FOR IRRIGATION AND ENHANCEMENT SHALL CONFORM TO THE ARIZONA GROUNDWATER CODE, ARIZONA REVISED STATUTES 45, CHAPTER 2.
2. IRRIGATION PLAN IS SCHEMATIC AND DRAWN FOR GRAPHIC CLARITY. INSTALL EQUIPMENT WITHIN PLANTING AREAS AND ADJACENT TO WALKWAYS WHEREVER POSSIBLE.
3. IRRIGATION SYSTEM IS DESIGNED FOR A MINIMUM PRESSURE OF 43 PSI. PRIOR TO START OF IRRIGATION WORK, CONTRACTOR SHALL VERIFY EXISTING WATER PRESSURE AT THE METER (ASSUMED TO BE 43 PSI) AND NOTIFY OWNER'S REPRESENTATIVE OF ANY DISCREPANCY BETWEEN EXISTING PRESSURE AND DESIGN PRESSURE BEFORE PROCEEDING WITH WORK. NOTIFY LANDSCAPE ARCHITECT IF PRESSURE EXCEEDS 120 PSI.
4. COORDINATE WITH OTHER WORK AS REQUIRED TO PROVIDE POWER TO IRRIGATION CONTROLLERS.
5. MAKE IRRIGATION POINTS OF CONNECTION TO WATER LINES AS INDICATED ON PLANS AND COORDINATE WITH OTHER WORK AS REQUIRED.

YEAR	DAYS	FREQUENCY	TIME (HRS.)	TOTAL WATER
3	MON. WED. FRI.	1	2.75	3,224,064
4	MON. THUR.	1	3	2,418,048
5	WED.	1	4	1,612,032

IDEALLY, THE CONTROLLER SHOULD BE ADJUSTED MONTHLY. INSPECT THE TIME CLOCK AT LEAST ONCE A MONTH TO MAKE SURE IT IS OPERATING PROPERLY. LESS IRRIGATION IS GENERALLY REQUIRED IN DECEMBER, JANUARY, AND FEBRUARY.


- EXACT LOCATION OF CONTROLLERS TO BE APPROVED PRIOR TO INSTALLATION.
7. CONTRACTOR RESPONSIBLE FOR ALL SLEEVES. WHETHER INDICATED ON THESE PLANS OR NOT. NOT INSTALL ALL PIPE AND WIRE UNDER PAVING OR WALLS IN SLEEVE, SIZE AS REQUIRED. COORDINATE WITH OTHER WORK AS REQUIRED.
8. INSTALL 3/4" EMITTER TUBING WITH DRIP EMITTERS AS REQUIRED, TO PROVIDE IRRIGATION TO ALL NEW SHRUBS AND TREES PER PLANTING PLAN
9. LAY OUT EMITTER TUBING PARALLEL TO TOPOGRAPHY WHEREVER POSSIBLE. INSTALL AUTOMATIC FLUSH TYPE END CAP AT ENDS OF ALL 3/4" LINES AND FLUSH THOROUGHLY BEFORE INSTALLING EMITTERS. BURY TUBING AT AN 8" DEPTH.
0. FOR SHRUBS AND VINES: INSTALL SINGLE OUTLET EMITTERS AS FOLLOWS:
 - (2) 1-GPH EMITTERS AT EACH 5 GALLON PLANT
 - (1) 1-GPH EMITTERS AT EACH 1 GALLON PLANT
 - (1) 0.5-GPH EMITTERS AT EACH SUCCULENT. MULTI-OUTLET EMITTERS MAY BE SUBSTITUTED FOR INDIVIDUAL EMITTERS.
1. FOR TREES: INSTALL MULTI-OUTLET EMITTER AS FOLLOWS:
 - (8) 1-GPH EMITTERS AT EACH 48" BOX /TRANSPLANTED TREE
 - (4) 1-GPH EMITTERS AT EACH 24" BOX /36" BOX
 - (4) 1-GPH EMITTERS AT EACH 15 GALLON
2. SINGLE OUTLET EMITTER - RAIN BIRD XB-10PC. OR EQUAL MULTI-OUTLET EMITTER - RAIN BIRD XBT-10-6, OR EQUAL. MULTI-OUTLET EMITTERS MAY BE SUBSTITUTED FOR INDIVIDUAL EMITTERS.
3. USE SHORT PIECES OF 1/4" DISTRIBUTION TUBING (MAXIMUM LENGTH 6') TO EXTEND EMITTERS TO EACH ROOTBALL. HOLD IN PLACE WITH STAKES.
4. REVIEW EMITTER LAYOUT WITH LANDSCAPE ARCHITECT AND ADJUST NUMBER OF EMITTERS FOR SPECIFIC PLANTS THAT REQUIRE GREATER OR LESSER VOLUME OF WATER THAN INDICATED.
5. IRRIGATION CONTRACTOR SHALL SUBMIT AN IRRIGATION SCHEDULE FOR REVIEW.
6. ALL BURIED IRRIGATION PIPE GREATER THAN TWO INCHES IN DIAMETER SHALL HAVE A #18 U TYPE TRACER WIRE ATTACHED SECURELY TO IT AT 8 FT. INTERVALS. AT THE TERMINATION POINT ATTACH WIRE SECURELY TO PIPE AND PROVIDE TWELVE INCHES OF TRACER WIRE ACCESSIBLE ABOVE GRADE.

SYMBOL	DESCRIPTION	MANUFACTURER/MODEL	COMMENTS
	WATER METER	PER LOCAL CODE	SERVICE LINE SIZE - SEE WATER PLANS
	IRRIGATION CONTROLLER	RAIN BIRD EXP-LXD TWO WIRE CONTROL SYSTEM WITH REMOTE CONTROL	PEDESTAL MOUNT IN RAIN BIRD LXMMPD CABINET AT LOCATION SHOWN
	BACKFLOW PREVENTER IN ENCLOSURE	FEBCO 825Y, SIZE AS INDICATED	GUARDSHACK ENCLOSURE, COLOR: WOODLAND TAN. INSTALL ON 4" THICK CONCRETE SLAB PER MANUFACTURERS RECOMMENDATIONS. PROVIDE R30 INSULATION BLANKET
	GATE VALVE	NIBCO T-113K BRASS GATE VALVE	LINE SIZE, IN VALVE BOX * BOX SIZE: AMETEK 10" ROUND, OR EQUAL.
	QUICK COUPLER	RAIN BIRD 33DRC	IN VALVE BOX * BOX SIZE: AMETEK 10" ROUND, OR EQUAL. PROVIDE (3) KEYS.
	MASTER VALVE	(1) RAIN BIRD BPE-NP-HAN	
	FLOW SENSOR	(1) RAIN BIRD FS	
	REMOTE CONTROL VALVE ASSY. (TREE/SHRUB)	CONTROL VALVE: IRRITROL 700 P SERIES BALL VALVE: KBI PVC BALL VALVE PRESSURE REGULATOR: RAIN BIRD PSH-M30X-100 WYE FILTER: RAIN BIRD RBY-150-MX	SIZE PER PLAN-INSTALL IN VALVE BOX * BOX SIZE: AMETEK "JUMBO", OR EQUAL.
	REMOTE CONTROL VALVE ASSY. (TURF)	CONTROL VALVE: IRRITROL 700 P SERIES BALL VALVE: KBI PVC BALL VALVE	SIZE PER PLAN IN VALVE BOX* AMETEK "STANDARD". PROVIDE D.C. SOLENOIDS
	POP-UP TURF ROTOR (ADJUSTABLE RADIUS)	HUNTER, I-20-06-SS <u>PSI</u> <u>RADIUS</u> <u>GPM</u> 1.5 SR BLACK NOZZLE 30 23' 1.1	ADJUST/CHANGE NOZZLES AS NEEDED TO ACHIEVE COMPLETE COVERAGE AND MINIMIZE OVERSPRAY ONTO WALKS, WALLS, AND ROADWAYS.
	MULTI-OUTLET EMITTER (TREES)	RAIN BIRD XB-10-6 MULTI-OUTLET XERI-BUG	NOT SHOWN ON PLAN. PROVIDE (1) TO EACH TREE. BOX SIZE: AMETEK 6" ROUND, OR EQUAL.
	SINGLE EMITTER (SHRUBS)	RAIN BIRD XB-10PC (1 GPH)	NOT SHOWN ON PLAN. PROVIDE (2) TO EACH SHRUB.
	MAIN LINE	SCH. 40 PVC PIPE	SIZE 3" UNLESS OTHERWISE NOTED SCH. 80 FITTINGS. SOLVENT WELD.
	LATERAL LINE (PVC)	CLASS 200 PVC PIPE	REFER TO PIPE SIZE CHART-THIS SHEET-FOR LATERAL LINE SIZE. SOLVENT WELD. SCH. 40 FITTINGS
	LATERAL LINE (POLY)	3/4" POLYETHYLENE (BY U.S. PLASTICS OR EQUAL)	MAX. RUN 250 FT.
	SLEEVE	SCH. 40 PVC PIPE	SIZE TO BE 2X DIAMETER OF PIPE BEING SLEEVED (MIN. 4")
	FLUSH END CAP	SEE DETAIL	LOCATE AT END OF EVERY LATERAL RUN IN VALVE BOX, 6" ROUND SIZE *

* VALVE BOXES TO BE COLOR TAN.

A-*	STATION NUMBER
1"	VALVE SIZE
2.0	FLOW (GPM)
TREE	PLANTING TYPE

FLOW	PIPE SIZE
1-6 GPM	3/4"
6.1-10 GPM	1"
10.1-16 GPM	1-1/4"
16.1-24 GPM	1-1/2"
24.1-46 GPM	2"



The
WLB
Group
Inc. **WLB**

Engineering Planning Surveying
Landscape Architecture Urban Design
Offices located in Tucson, Phoenix and
Flagstaff, Arizona, and Las Vegas, Nevada.
4444 East Broadway
Tucson, Arizona (520) 881-7480

LOTS 1 THROUGH 80 AND COMMON AREA "A" (PRIVATE STREETS) & "B" (LANDSCAPED & NATURAL OPEN SPACE DRAINAGE & RECREATION AREA)

Sheet Title File:Q:\116028 Shannon 80\A-002 - Platting\02 Landscape\08 FLP\Plans\Shannon 80 FLP 15 irr legend.dwg

No.	Date	Item	Scale	N/A
			Job No.	116028-A002
			Date	JULY 2020
			Designed By	PNR
Revisions			Checked By	GLG

Call at least two full working days
before you begin excavation.

ARIZONA 811
Arizona Blue Stake, Inc.


Dial 8-1-1 or 1-800-STAKE-IT (782-5348)
In Maricopa County: (602) 263-1100




OV1701617
OV1701072
G-2019-042
P19WI00026

Sheet 15


of **22**



DRIP IRRIGATION
SCALE 1"= 100'



0' 100' 200' 300'



TURF IRRIGATION
SCALE 1"= 30'

The WLB Group Inc. **WLB**

Engineering Planning Surveying
Landscape Architecture Urban Design
Offices located in Tucson, Phoenix and
Flagstaff, Arizona, and Las Vegas, Nevada.
444 East Broadway
Tucson, Arizona (520) 881-7480

SHANNON 80

LOTS 1 THROUGH 80 AND COMMON AREA "A" (PRIVATE STREETS) & "B" (LANDSCAPED & NATURAL OPEN SPACE,
DRAINAGE & RECREATION AREA)

Project

FINAL LANDSCAPE PLAN IRRIGATION PLAN

Sheet Title: File: Q:\116028 Shannon 80A-002 - Platting\02 Landscape\08 FLP\Plans\Shannon 80 FLP 16 irr.dwg

No.	Date	Item


Scale	AS NOTED
Job No.	116028-A002
Date	JULY 2020
Designed By	PNR
Checked By	GLG



RELATED CASE

OV1701617
OV1701072
G-2019-042
P19W100026


Sheet 16
of 22



NOTE: ALL IRRIGATION SUB-LATERALS AND DRIP-TUBING SHOULD MAXIMIZE USE OF SLOPE TO REDUCE PRESSURE LOSS DUE TO ELEVATION CHANGE - ORIENT RUNS DOWNHILL, AVOID UPHILL RUNS. MAXIMUM RUN SHOULD NOT EXCEED 250'.

12 SHRUB ZONE ON SLOPE DETAIL


SCALE: NTS



LOCATE 8" MIN. FROM IMPERMEABLE SURFACES


13 POP-UP ROTOR

SCALE: NTS



14 VALVE BOX PLACEMENT


SCALE: NTS



15 THRUST BLOCK DETAIL

SCALE: NTS


PIPE SIZE	IRRIGATION PIPE	
	Tee, Deadend, 90 Deg. bend	45 & 22.5 Deg.
2" & LESS	NOT REQUIRED	NOT REQUIRED
3"	1.5 SF	1 SF
4"	3 SF	3 SF
6"	4 SF	3 SF



NOTE: IF PLANTED ON SLOPE, PLACE EMITTER ON UPHILL SIDE OF PLANT


8 SINGLE OUTLET EMITTER

SCALE: NTS




9 EMITTER PLACEMENT AT TREES

SCALE: NTS



10 FLUSH END ASSEMBLY


SCALE: NTS



11 QUICK COUPLER


SCALE: NTS

NOTE: TAPE & BUNDLE TUBING AND WIRING AT 10' INTERVALS
ALL 120 VOLT WIRING IN CONDUIT TO BE INSTALLED AS PER LOCAL CODES
ALL PVC PIPING TO BE SNAKED IN TRENCHES AS SHOWN
PIPE BEDDING MATERIAL TO BE ROCK & DEBRIS FREE, BACKFILL IN 6" LIFTS, PUDDLE WITH WATER, BETWEEN LIFTS.
THRUST BLOCK ALL DIRECTION CHANGES OF THE MAINLINE WITH 1 C.F. OF 3000 P.S.I. CONCRETE



4 TRENCH


SCALE: NTS



NOTE: BUNDLE & TAPE WIRE EVERY 10 FT. SEAL WIRE ENDS WITH SPLICING MATERIAL.

5 REMOTE CONTROL TURF VALVE


SCALE: NTS



NOTE: BUNDLE & TAPE WIRE EVERY 10 FT. SEAL WIRE ENDS WITH SPLICING MATERIAL.


6 DRIP VALVE ASSEMBLY

SCALE: NTS



7 MULTI OUTLET EMITTER


SCALE: NTS



NOTE: GROUND CONTROLLER PER CONTROLLER MANUFACTURER RECOMMENDATIONS AND PER LOCAL CODE.

1 PEDESTAL-MOUNT CONTROLLER


SCALE: NTS



NOTES: PROVIDE BACKFLOW TESTING PER WATER COMPANY STANDARDS. PROVIDE TAN COLOR R30 "FROSTGUARD" BLANKET

2 BACKFLOW PREVENTER

SCALE: NTS



3 ISOLATION VALVE


SCALE: NTS



RELATED CASE

OV1701617
OV1701072
G-2019-042
P19W100026






- NOTES:
- REFER TO MANUFACTURER'S WIRING DIAGRAMS.

6 SURGE PROTECTOR CONNECTION/GROUNDING


NTS



- NOTES:
- SPACE PULL-BOXES AT 250' MAX. OR AT CHANGE OF DIRECTION 90° OR SHARPER EACH
 - NO SPLICES PERMITTED


7 COMMUNICATIONS CABLE PULL-BOX

NTS



8 SYSTEM SCHEMATIC-STRAIGHT LINE CONFIGURATION


NTS



- NOTES:
- REFER TO MANUFACTURER'S WIRING DIAGRAMS
 - PLACE 3 FEET OF EXTRA WIRE IN EVERY VALVE BOX FOR EASIER SERVICING.
 - MAXIMUM LENGTH OF SECONDARY WIRE PATH (14 AWG) FROM FIELD DECODER TO SOLENOID IS 450 FEET.

4 DRIP CONTROL VALVE ASSEMBLY & DECODER


NTS



- NOTES:
- REFER TO MANUFACTURER'S WIRING DIAGRAMS
 - PLACE 3 FEET OF EXTRA WIRE IN EVERY VALVE BOX FOR EASIER SERVICING.
 - MAXIMUM LENGTH OF SECONDARY WIRE PATH (14 AWG) FROM FIELD DECODER TO SOLENOID IS 450 FEET.


5 TURF CONTROL VALVE ASSEMBLY & DECODER

NTS




1 PEDESTAL MOUNT CONTROLLER

NTS



2 CONTROLLER GROUNDING

NTS



3 MASTER VALVE & FLOW SENSOR

NTS



RELATED CASE #

OV1701617
OV1701072
G-2019-042
P19W100026

IRRIGATION
PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Codes and Standards:
1. NFPA 70: National Electric Code
 2. American Water Works Association (AWWA) for pipe and fitting manufacturer compliance
 3. American Society for Testing and Materials International (ASTM) for pipe and fitting manufacturer compliance

1.2 SUMMARY

- A. Section Includes:
1. Piping.
 2. Encasement for piping.
 3. Manual valves.
 4. Automatic control valves.
 5. Transition fittings.
 6. Miscellaneous piping specialties.
 7. Quick couplers.
 8. Drip irrigation specialties.
 9. Controllers.
 10. Boxes for automatic control valves.
 11. Backflow Preventer.
 12. Evapo-transpiration Sensor or Weather Station.

1.3 DEFINITIONS

- A. Circuit Piping: Downstream from control valves to sprinklers, specialties, and drain valves. Piping is under pressure during flow.
- B. Drain Piping: Downstream from circuit-piping drain valves. Piping is not under pressure.
- C. Main Piping: Downstream from point of connection to water distribution piping to, and including, control valves. Piping is under water-distribution-system pressure.

1.4 PERFORMANCE REQUIREMENTS

- A. Irrigation zone control shall be automatic operation with controller and automatic control valves.
- B. Location of Emission Devices and Specialties: It is hereby specified that the system shall be complete and fully operational covering 100% of the planted area.
- C. Minimum Working Pressures: The following are minimum pressure requirements for piping, valves, and specialties, unless otherwise indicated:
1. Minimum Pressure at drip emission devices: 15 psi.
 2. Minimum pressure at spray heads shall be per manufacturer's recommendations.

1.5 CLOSEOUT SUBMITTALS

- A. As-built Drawings: Document the piping sizes and layout, each zone, zone type, number of heads in each zone, note emitter spacing. In addition closeout submittals should include:
1. Controller Keys.
 2. Controller manual.
 3. Quick Coupler key.
 4. As-built drawings.
Submit 2 copies: one 11"x17" laminated copy, one full-sized copy. Submit one electronic copy in .pdf format
 5. Controller schedule.
 6. Backflow preventer test certificate.
 7. Warranty documents for the irrigation system.
 8. Backflow preventer enclosure keys.

1.6 DELIVERY, STORAGE, AND HANDLING

- A. Store plastic piping protected from direct sunlight. Support to prevent sagging and bending.

1.7 PROJECT CONDITIONS

- A. Interruption of Existing Water Service: Do not interrupt water service to facilities occupied by Owner or others unless permitted under the following conditions and then only after arranging to provide temporary water service according to requirements indicated:
1. Notify Owner's Representative no fewer than two (2) days in advance of proposed interruption of water service.
 2. Do not proceed with interruption of water service without Owner's Representative's permission.

1.8 MAINTENANCE SERVICE

- A. Initial Maintenance Service: Provide full maintenance by skilled employees of irrigation installer. Maintain as required in Part 3. Begin maintenance immediately after each area is planted and continue until not less than the following period:
1. Maintain until 30 days after handover and approved at "30 Day Walk."

1.9 WARRANTY

- A. Special Warranty: Installer agrees to repair or replace irrigation and accessories tha fail in materials or workmanship within on-year warranty period.

PART 2-PRODUCTS

2.1 PIPES, TUBES, AND FITTINGS

- A. Comply with requirements for applications of pipe, tube, and fitting materials, and for joining methods for specific services, service locations, and pipe sizes.
- B. PVC Pipe: ASTM D 1785, PVC 1120 compound, Schedule 40.
1. PVC Socket Fittings: ASTM D 2466, Schedule 40.
 2. PVC Threaded Fittings: ASTM D 2464, Schedule 80.
 3. PVC Socket Unions: Construction similar to MSS SP-107, except both headpiece and tailpiece shall be PVC with socket ends.

2.2 PIPING JOINING MATERIALS

- A. Solvent Cements for Joining PVC Piping: ASTM D 2564. Include primer according to ASTM F 656.
- B. Plastic, Pipe-Flange Gasket, Bolts, and Nuts: Type and material recommended by piping system manufacturer unless otherwise indicated.

2.3 ISOLATION VALVES

Isolation Valves shall be as indicated on the irrigation plans.

2.4 AUTOMATIC CONTROL VALVES

- A. Automatic Circuit Control Valves shall be as indicated on the irrigation plans.

2.5 TRANSITION FITTINGS

- A. General Requirements: Same size as, and with pressure rating at least equal to and with ends compatible with, piping to be joined. Provide products compatible with piping, valves, heads and controllers for proposed system which conform to standards of practice.

2.6 SPRINKLERS

- A. Sprinklers shall be as indicated on the irrigation plans.
1. Install for uniform "Head to Head" coverage over entire spray area indicated.

2.7 QUICK COUPLERS

- A. Quick-Coupling Valves shall be as indicated on the irrigation plans.

2.8 DRIP IRRIGATION SPECIALTIES

- A. Drip Tubes:
1. Tubing:
 - a. Body Material: PE or vinyl.
 - b. Mounting: On riser, inserted into lateral line at set intervals.
 2. Capacities and Characteristics: As indicated on the irrigation plans.
- B. Emission Device:
1. Emitter: As indicated on Irrigation Plans.
- C. Off-Ground Supports: Plastic stakes.
- D. Application Pressure Regulators: Brass or plastic housing, NPS ¾, with corrosion-resistant internal parts; capable of controlling outlet pressure to approximately 30 psig.
- E. Filter Units: Brass or plastic housing, with corrosion-resistant internal parts; of size and capacity required for devices downstream from unit.
- F. Air Relief Valves: Brass or plastic housing, with corrosion-resistant internal parts.
- G. Vacuum Relief Valves: Brass or plastic housing, with corrosion-resistant internal parts.

2.9 CONTROLLERS

- A. Controller shall be as indicated on the irrigation plans.
1. Provide 2 spare - unused controller zones. Provide expansion modules as necessary to operate number of valves indicated on irrigation plans.
- B. Mount at location indicated on the irrigation plans.

2.10 BOXES FOR AUTOMATIC CONTROL VALVES AND FLUSH ENDS

- A. Plastic Boxes shall be as indicated on the irrigation plans. Description: Box and cover, with open bottom and openings for piping; designed for installing flush with grade.
1. Size: 10" Round-Isolation Valve; "Jumbo" Rectangular-Control Valve. One Valve per Box.
 2. Shape: Round and Rectangular.
 3. Sidewall Material: PE.
 4. Cover Material: PE.
 5. Lettering: Irrigation Valve Box.

2.11 BACKFLOW PREVENTER

- A. Provide backflow preventer on concrete pad in lockable enclosure as indicated on the irrigation plans.
- a. Provide R-30 Insulation cover.

2.12 WEATHER SENSOR

1. Weather Sensor shall be as indicated on the irrigation plans.

PART 3 - EXECUTION

3.1 EARTHWORK

- A. Install warning tape directly above pressure piping, 12 inches below finished grades, except 6 inches below subgrade under pavement and slabs.
- B. Provide minimum cover over top of underground piping according to the following:
1. Irrigation Main Piping: Minimum depth of 18 inches
 2. Circuit Piping: 12 inches.
 3. Drain Piping: 12 inches.
 4. Sleeves: 24 inches.

PART 3 - EXECUTION

3.1 EARTHWORK

- A. Install warning tape directly above pressure piping, 12 inches below finished grades, except 6 inches below subgrade under pavement and slabs.
- B. Provide minimum cover over top of underground piping according to the following:
1. Irrigation Main Piping: Minimum depth of 18 inches
 2. Circuit Piping: 12 inches.
 3. Drain Piping: 12 inches.
 4. Sleeves: 24 inches.

3.2 PREPARATION

- A. Set stakes to identify locations of proposed irrigation system. Obtain Owner's Representative's approval before excavation. Notify Owner's Representative of any conflicts prior to installation.

3.3 PIPING INSTALLATION

- A. Location and Arrangement: Drawings indicate location and arrangement of piping systems.
- B. Install piping at minimum uniform slope of 0.5 percent down toward drain valves.
- C. Install piping free of sags and bends.
- D. Install group of pipes parallel to each other, spaced to permit valve servicing.
- E. Install fittings for changes in direction and branch connections.
- F. Install unions adjacent to valves and to final connections to other components with NPS 2 or smaller pipe connection.
- G. Install flanges adjacent to valves and to final connections to other components with NPS 2-1/2 or larger pipe connection.
- H. Install expansion loops in control-valve boxes for plastic piping.
- I. Lay piping on solid sub-base, uniformly sloped without humps or depressions.
- J. Install PVC piping in dry weather when temperature is above 40 deg F. Allow joints to cure at least 24 hours at temperatures above 40 deg F before testing.
- K. Install pressure regulators with shutoff valve and strainer on inlet and pressure gauge on outlet. Install shutoff valve on outlet. Install aboveground or in control-valve boxes.
- L. Install piping in sleeves under parking lots, roadways, and sidewalks.
- M. Install sleeves made of 4" Schedule 40 PVC pipe and socket fittings, and solvent-cemented joints.
- N. Install transition fittings for plastic-to-metal pipe connections according to the following:
1. Underground Piping:
 - a. NPS 1-1/2 and Smaller: Plastic-to-metal transition fittings.
 - b. NPS 2 and Larger: AWWA transition couplings.
 2. Aboveground Piping (Not permitted in markets of freezing environments):
 - a. NPS 2 and Smaller: Plastic-to-metal transition fittings and unions.
 - b. NPS 2 and Larger: Use dielectric flange kits with one plastic flange.

3.4 JOINT CONSTRUCTION

- A. Ream ends of pipes and tubes and remove burrs. Bevel plain ends of steel pipe.
- B. Remove scale, slag, dirt and debris from inside and outside of pipe and fittings before assembly.
- C. PVC Piping Solvent-Cemented Joints: Clean and dry joining surfaces. Join pipe and fittings according to the following:
1. Comply with ASTM F 402 for safe-handling practice of cleaners, primers, and solvent cements.
 2. PVC Pressure Piping: Join schedule number, ASTM D 1785, PVC pipe and PVC socket fittings according to ASTM D 2672. Join other-than-schedule-number PVC pipe and socket fittings according to ASTM D 2855.
 3. PVC Non-pressure Piping: Join according to ASTM D 2855.

3.5 VALVE INSTALLATION

- A. Valve (All) Location:
1. Valve and Control Boxes must be a minimum 3' behind face of curb or sidewalk.
 2. Top of all Irrigation Boxes must be at grade or slightly above.
- B. Above-ground Valves: Install as components of connected piping system.

3.6 SPRINKLER INSTALLATION

- A. Install sprinklers after hydrostatic test is completed.
- B. Install sprinklers as indicated in the Irrigation Plans, otherwise at manufacturer's recommended heights.
- C. Locate part-circle sprinklers to maintain a minimum distance of 8 inches from impermeable surfaces, IE. walls, headers, sidewalks and other boundaries unless otherwise indicated.

3.7 DRIP IRRIGATION SPECIALTY INSTALLATION

- A. Install freestanding emitters on pipe riser to mounting height indicated.
- B. Install manifold emitter systems with tubing to emitters. Plug unused manifold outlets. Install emitters on off-ground supports at height indicated.
- C. Install multiple-outlet emitter systems with tubing to outlets. Plug unused emitter outlets. Install outlets on off-ground supports at height indicated.
- D. Install drip tubes with direct-attached emitters on in 6" round valve boxes.
- E. Install drip tubes with remote-discharge in 6" round valve boxes. with outlets on off-ground supports at height indicated.
- F. Install off-ground supports of length required for indicated mounted height of device.
- G. Install drip assembly pressure regulator and filter below grade in a 10" round valve box as shown on the detail. Locate within 2' of the electronic control valve.

3.8 AUTOMATIC IRRIGATION-CONTROL SYSTEM INSTALLATION

- A. Equipment Mounting: Install interior controllers in Low Voltage Cabinet.
1. Place and secure anchorage devices. Use setting drawings, templates, diagrams, instructions, and directions furnished with items to be embedded.
 2. Install anchor bolts to elevations required for proper attachment to supported equipment.
- B. Install control wire in same trench as irrigation piping and at least 2 inches beside piping. Provide conductors of size not smaller than recommended by controller manufacturer. Install cable in separate sleeve under paved areas.

3.9 CONNECTIONS

- A. Drawings indicate general arrangement of piping, fittings, and specialties.
- B. Install piping adjacent to equipment, valves, and devices to allow service and maintenance.
- C. Connect wiring between controllers and automatic control valves.

3.10 FIELD QUALITY CONTROL

- A. Tests and Inspections:
1. Leak Test: After installation, charge system and test for leaks. Repair leaks and retest until no leaks exist.
 2. Operational Test: After electrical circuitry has been energized, operate controllers and automatic control valves to confirm proper system operation.
 3. Test and adjust controls and safeties. Replace damaged and malfunctioning controls and equipment.
- B. Any irrigation product will be considered defective if it does not pass tests and inspections.

3.1 START UP SERVICE

- A. Perform startup service.
1. Complete installation and startup checks according to manufacturer's written instructions.
 2. Verify that controllers are installed and connected according to the Contract Documents.
 3. Verify that electrical wiring installation complies with manufacturer's submittal.

3.12 ADJUSTING



- A. Adjust settings of controllers.
- B. Adjust automatic control valves to provide flow rate at rated operating pressure required for each irrigation circuit.
- C. Adjust devices, except those intended to be mounted aboveground, so they will be flush with finish grade.

3.13 CLEANING

- A. Flush dirt and debris from piping before installing emission devices.

3.14 DEMONSTRATION

- A. Coordinate an operating demonstration and acceptance meeting with Owner's Representative.




RECREATION KEYNOTES

- 1 RAMADA. 24' x 24' AMERICANA "NAVAJO" MODEL PRE-ENGINEERED METAL SHADE STRUCTURE WITH METAL ROOF SYSTEM. COLORS: 'LIGHT GREEN' FOR ROOF PANELS, 'TAN' FRAME.
- 2 PICNIC TABLE: WABASH SIGNATURE SERIES SG210P. 6 FT. LONG PERFORATED. IN-GROUND-MOUNT PER MANUFACTURER RECOMMENDATIONS. COLOR: TEXTURED BRONZE POWDER COAT. AVAILABLE FROM DAVE BANG (800) 456-7903.
- 3 BARBECUE: PW ATHLETIC MODEL# 1140-00 15" X 20" GRILL COLOR: BLACK. IN-GROUND MOUNT PER MANUFACTURER'S RECOMMENDATIONS. AVAILABLE FROM DAVE BANG (800) 456-7903
- 4 TRASH RECEPTACLE : WABASH T13B33S WITH SOLID BONNET. COLOR: TEXTURED BRONZE POWDER COAT. SURFACE MOUNT PER MANUFACTURER'S RECOMMENDATIONS. AVAILABLE FROM DAVE BANG (800) 456-7903.
- 5 BENCH: WABASH DEWART COLLECTION #DE1113C. 6FT. LONG HORIZONTAL SLAT. SURFACE-MOUNT PER MANUFACTURER RECOMMENDATIONS. COLOR: TEXTURED BRONZE POWDER COAT. AVAILABLE FROM DAVE BANG
- 6 BIKE LOOPS (2): PW ATHLETIC 1700-00. COLOR: "520 BRONZE" POWDER COAT. SURFACE MOUNT PER MANUFACTURER'S RECOMMENDATIONS. AVAILABLE FROM DAVE BANG (800) 456-7903.
- 7 DRINKING FOUNTAIN WITH DRAINAGE SUMP: MOST DEPENDABLE FOUNTAINS MODEL 440 SM SHOWN WITH SS SURFACE CARRIER 646-022b. INSTALL PER MANUFACTURER'S RECOMMENDATIONS. COLOR TO BE "TEXTURED COPPER". SEPARATE BUILDING SERVICES DEPARTMENT PERMIT REQUIRED.
- 8 TEE INTO LIFT STATION SUPPLY LINE & INSTALL ONE-INCH WATER LINE TO DRINKING FOUNTAIN PER LOCAL CODES. SEPARATE BUILDING SERVICES DEPT. PERMIT REQUIRED.
- 9 BACKFLOW PREVENTER ASSEMBLY: FEBCO 825Y. ISOLATION VALVE: NIBCO T113-K. ENCLOSURE: GUARDSHACK GS-1N (WOODLAND TAN COLOR) PROVIDE R30 "FROSTGUARD" BLANKET.
- 10 PLAY EQUIPMENT: 2-12 YRS. BY MIRACLE PLAYGROUNDS DESIGN MODEL # : R001_43013481447. COLORS TO BE DETERMINED. COORDINATE WITH MANUFACTURER TO ENSURE CORRECT FALL ZONES AND ADA ACCESSIBILITY. AVAILABLE FROM MIRACLE PLAYGROUND SALES. CONTACT MONTE CORLEY (monte@miracleplayground.com)
- 11 SAFETY SURFACE. "FIBAR" SYSTEM 112 WITH (3) FIBARMATS. INSTALL PER MANUFACTURER'S RECOMMENDATIONS. CONTACT MONTE CORLEY AT MIRACLEPLAYGROUND [monte@miracleplayground.com]
- 12 PLAYGROUND SHADE SAILS: MIRACLE USA SHADE 3-POINT TENSION SAIL CLUSTER 3 TOPS, 5 POSTS, 90 MPH WIND LOAD. SAIL: "SHADESURE CLOTH. SAIL COLOR: "TERRACOTTA" AND "DESERT SAND", POST COLOR: "LIGHT IVORY". AVAILABLE FROM MIRACLE RECREATION. CONTRACTOR SHALL PROVIDE STRUCTURAL DRAWINGS & CALCULATIONS SEALED BY A STRUCTURAL ENGINEER LICENSED IN THE STATE OF ARIZONA. CONTACT MONTE CORLEY (monte@miracleplayground.com)
- 13 USE ZONE, TYPICAL. CONTRACTOR SHALL ENSURE USE ZONE IS COMPLETELY WITHIN SAFETY SURFACE AREA WITH NO OBSTRUCTIONS.
- 14 PARK SIGN DISPLAYING:
 - A. HOURS OF OPERATION.
 - B. PARK/RECREATIONAL AREA RULES.
 - C. TRESPASSING NOTICE FOR UNAUTHORIZED USERS, INCLUDING CITATION OF APPLICABLE ORDINANCES/STATUTES.
 - D. NOTICE THAT ALL DOGS MUST BE KEPT ON A LEASH
 - E. EMERGENCY (911) CONTACT INFORMATION TO REPORT SUSPICIOUS OR CRIMINAL ACTIVITY.
 - F. H.O.A. CONTACT INFORMATION TO REPORT MAINTENANCE OR SAFETY ISSUES
- 15 GREY CONCRETE SIDEWALK PER CIVIL ENGINEERING PLANS.
- 16 PLAYGROUND FENCE $\frac{3}{22}$
- 17 CONCRETE HEADER $\frac{2}{22}$
- 18 POTABLE WATER METER BY CIVIL PLANS
- 19 DECOMPOSED GRANITE: SEE PLANTING PLANS & LEGEND
- 20 STABILIZED DECOMPOSED GRANITE PATHWAY $\frac{4}{21}$
- 21 NATURAL GREY CONCRETE $\frac{2}{21}$
- 22 ACCESS RAMP $\frac{1}{22}$
- 23 "TUFFMATT" ZERO-FILL WEAR MAT. 30" X 48" AT SLIDE EXITS. INSTALL PER MANUFACTURER'S RECOMMENDATIONS. AVAILABLE FROM ZEAGER BROTHERS. www.zeager.com.
- 24 ACCESSIBLE PARKING SPACE BY CIVIL PLANS
- 25 CONCRETE MOWCURB $\frac{4}{22}$

NOTE: 1. PROVIDE EXPANSION JOINTS @ ALL CONSTRUCTION JOINTS.

1/2" RADIUS AT AT EDGES, 1/4" RADIUS AT ALL JOINTS.



EXPANSION JOINT: 1/2" THICK FIBER EXPANSION JOINT FILLER (NON-ASPHALTIC). EXTEND 1" MIN. BELOW BASE OF CONCRETE. APPLY ELASTOMERIC SEALANT OVER EXPANSION JOINT MATERIAL. COLOR TO MATCH ADJACENT CONCRETE


1-1/4" DEEP TROWELED SCORE / CONTROL JOINT, WITH 1/4" RADIUS AT EDGES.

1 CONCRETE JOINTS

SCALE: NTS


NOTE:

1. APPLY PRE-EMERGENT HERBICIDE TO SUBGRADE SURFACE.
2. SEE PLANT LEGEND FOR DECOMPOSED GRANITE DESCRIPTIONS.
3. FOLLOW STABILIZER MANUFACTURER'S RECOMMENDATIONS FOR INSTALLATION OF PATHWAY.




4 STABILIZED DECOMPOSED GRANITE PATHWAY

SCALE: NTS



7 BICYCLE PARKING

SCALE: NTS



2 CONCRETE PAVING

SCALE: NTS

BENCH PER PLANS:

SURFACE MOUNT


CONC. FOOTING 2500 PSI, (4)

2" DEPTH D.G.

FINISH GRADE

5 BENCH

SCALE: NTS




NOTES:

1. DO NOT SCALE DRAWINGS.
2. INSTALLATION TO BE COMPLETED IN ACCORDANCE WITH MANUFACTURER'S SPECS.
3. SEPARATE BUILDING SERVICES DEPARTMENT PERMIT REQUIRED FOR DRINKING FOUNTAIN AND ASSOCIATED WATER SERVICE WITH BACKFLOW PREVENTER.
4. PROVIDE ADA ACCESS AROUND DRINKING FOUNTAIN.

8 DRINKING FOUNTAIN WITH DRAINAGE SUMP


SCALE: NTS

NOTE: 1. PROVIDE EXPANSION JOINTS @ ALL CONSTRUCTION JOINTS.



EXPANSION / ISOLATION JOINT AT VERTICAL SURFACE

SCALE: NTS




NOTES:

1. SMOOTH TROWEL FINISH.
2. 1" DEEP SCORE/CONTROL JOINTS AT 5' O.C.
3. 1/4" ISOLATION JOINTS AT 40' ON CENTER, WITH BITUMINOUS JOINT FILLER.

6 6" CONCRETE HEADER


SCALE: NTS




NOTE: PROVIDE BACKFLOW TESTING PER WATER CO. STD. PROVIDE R30 "FROSTGUARD" BLANKET

9 BACKFLOW PREVENTER

SCALE: NTS




SECTION




PLAN

1 ACCESS RAMP @ SAFETY SURFACE

SCALE: NTS




2 CONCRETE PLAYGROUND EDGE & SAFETY SURFACE



FENCE COLOR: TO MATCH ENTRY GATE

3 PLAYGROUND FENCE

SCALE: NTS



NOTES:

1. SMOOTH TROWEL FINISH ALL EXPOSED SURFACES.
2. $\frac{1}{2}$ " DEEP SCORED CONTROL JOINTS AT 5' ON CENTER.
3. $\frac{1}{4}$ " WIDE EXPANSION JOINTS AND BITUMINOUS JOINT FILLER AT 40' ON CENTER.

4 CONCRETE MOWCURE

SCALE: NTS