

COMPRESSIVE STRENGTH TEST REPORT

Sample Date: 05/17/2024 Material: CLSM
Size: Cylinder 4x8
Lab No.: TUC-4397
Project Set No.: 5

Ninyo & Moore

Geotechnical and Environmental Sciences Consultants
1991 East Ajo Way, Suite 145
Tucson AZ 85713
520.577.7600 | www.ninyoandmoore.com

Client
Pima County
Attn: Rogelio Flores

Project
Rancho Vistoso Valley Vista Sewer Repair
601 E. Kalalau Dr.
Oro Valley AZ 85755
Project Number: 608157001

Field Test Data

Truck No.: 8075 Ticket No.: 1442978
Batch Time: 10:42am
Cast Time: 12:15pm Age (min.): 93
Load Vol.: 4 cy Cumulative Vol.: 4 yd³ of 4 tot. yd³
Water Added (gal): 4 Sampled From: Chute
Cast By: Jose Gonzalez
No. of Specimens: 5
Set No.: 1 Spec. Type: Cylinder

Mix Information

Supplier: Calportland
Mix No.: 400205
Product Desc.: Sand Slurry 2.0 Sack
Admixtures:
Max Agg. Size:
Plant: Ina Plant 119

Test	Result	Specified
Temp. (F):	72	
Air Temp. (F):	85	
Slump (in):	N/A	
Air Content (%)	N/A	
Unit Weight (pcf):	N/A	

Environmental Conditions:
Sunny, Arid, Dry, Light Breeze
High (F): 93
Low (F): 66

Mix Design Strength: 250
Specified Strength: 250 psi @ 28 days

Compressive Strength Test Method

Sample No.	Date Tested	Age, days	Maximum Load, lb	Average Diameter or Side, in.	Surface Area, in. ²	Compressive Strength psi	Average	Fracture Type	Cure	Cap Type	Tested By
1	May 24	7	990	3.99	12.50	80		Type 3	Lab	U	Michael Gause
2	Jun 14	28	1340	3.99	12.50	110		Type 3	Lab	U	Michael Gause
3	Jun 14	28	1330	3.99	12.50	110		Type 3	Lab	U	Michael Gause
4	Jun 14	28	1490	3.99	12.50	120	110	Type 3	Lab	U	Michael Gause
5	Jul 12	56	1530	3.99	12.50	120		Type 3	Lab	U	Michael Gause

Average compressive strength @ 28 days meets specified strength: ☐ Yes ☒ No

Structure Location / Placement Area:


Sewer Line 48ft - 58ft out of manhole #1 / Sewer Line 48ft - 58ft out of manhole #1

Comments:

Samples prepared and tested in accordance with:

ASTM C31, ASTM C39, ASTM C172, ASTM C511, ASTM C1064, ASTM C1231

TYPES OF FRACTURE



Reviewed By:

Print Date: 07/25/2024

Nick Moore / Senior Project Manager